MANUFACTURER'S DECLARATION OF CONFORMITY

We : TMSS FRANCE

Zone Industrielle n° 3
Boulevard Salvador Allende
16340 L'Isle d'Espagnac - FRANCE

declare under our own responsibility that the product(s) :

Telemecanique Sensors XUMRACAYM8 IO-Link Device

to which this declaration refers, conform to :

☒ IO-Link Interface and System Specification, V1.1.2, July 2013 (NOTE 1,2)

☒ IO Device Description, V1.1, August 2011

☐ Additional conformance to Device Profiles
(If checked refer to Part A on page 2)

☒ Conformance exceptions
(If checked refer to Part B on page 2)

The conformity tests are documented in the test report(s) :

184-00192_2_Test_report.pdf

Issued at **L'Isle d'Espagnac – FRANCE**, December 12th, 2023

Authorized signatory

Name : **Frédéric CORAZZA**
Title : **Products Certification Manager**

Signature :



Reproduction and all distribution without written authorization prohibited

NOTE 1 Relevant Test specification is CorrVersion 1.1.2, Feb. 2021 NOTE 2 Additional validity in Package 2015 and Corrigendum	MD-Version: V1.1.2 / 2022-01

Part A - Additional conformance to Device Profiles

Specification	
☐	IO-Link Common Profile Specification, V1.0, July 2017
☐	IO-Link Profile BLOB Transfer & Firmware Update Specification, V1.1, Sept. 2019
☐	IO-Link Smart Sensors 2nd Edition Specification, V1.0, March 2017
☐	IO-Link Smart Sensors 2nd Edition Specification, V1.1, Sept. 2021

Part B - Conformance exceptions

We herewith declare the following deviations to the related specifications	Reason
SDCI_TC_0019	The measured current IQHD at a supply voltage of 30 V exceeds the limit of 500 mA
SDCI_TC_0020	The measured current IQLD at a supply voltage of 30 V exceeds the limit of 500 mA